

Modification Highlights for VR-205-B

Executive Order

- Legal Language and Executive Order exhibits have been updated to reflect new revision level.
- Amended Exhibit 2, Page 2, #3. Removed where it said “and from” and now reads “Piping to the processor...”

Installation, Operation and Maintenance Manual (IOM)

- Amended section 14, page 14-8, 5.2. Added the phrase “or longer” after “5” and now reads “...5” or longer Legs”.
- Amended section 14, page 14-14 with an updated electrical schematic that correctly displays “1 Hour TIMER” instead of “24 Hour TIMER”.
- Made other minor changes for clarity and consistency.